



October 2, 2015

City of Richmond
Urban Design Committee
900 East Broad Street
Room 510
Richmond, VA 23219

RE: Response to UDC/Planning Commission Comments from September 9, 2015 PC Meeting Minutes

UDC/PC Comment #11: *That the final plans include a lighting plan for the stations, to include make, model and finish of any light fixture; light source and light color temperature. LED lights with a color temperature of 3000k are recommended. The lighting plan should also include a representative photometric diagram for at least one of the stations.*

Applicant Response: The technical requirements documents that are being prepared by the design team will include a representative photometric diagram for at least one station and will instruct that LED lights with a color temperature of 3000K are to be used at the stations.

SUPPORTING DOCUMENTATION

None