

October 2, 2015

City of Richmond
Urban Design Committee
900 East Broad Street
Room 510
Richmond, VA 23219

RE: Response to UDC/Planning Commission Comments from September 9, 2015 PC Meeting Minutes

UDC/PC Comment #16: *That the BRT planning team considers more options to uplift the BRT stations.*

Applicant Response: The design team is working on details to provide uplift to the ceiling without throwing excess light into the surrounding area. The details are being developed to wash the ceiling in light generated from the linear lighting brackets currently providing downlight to the station. The sides of these brackets will be perforated or bent to throw light onto the ceiling, as well as provide the downlight they are currently providing. These changes will be incorporated into the technical requirement documents that will be provided to the design builder.

SUPPORTING DOCUMENTATION

Rendering indicating linear lighting brackets that will be modified.

